






















Nr. Crt.	Localizare proba	Imagine	Temperatura interioara (°C)	Temperatura suprafata			Temperatura referinta camera (°C)	Coeficient emisivitate
				Minim (°C)	Maxim (°C)	Gradient de temperatura (°C)		
1.	Altar		7	3	12	9	30	1
2.	Altar 2		7	4	12	8	30	1
3.	Acoperis Altar		7	5	13	8	30	1





4.	Altar 3		7	5	13	8	30	1
5.	Altar 4		7	3	11	8	30	1
6.	Altar 5		7	3	12	9	30	1
7.	Altar 6		7	3	12	9	30	1




8.	Altar 7		7	2	11	9	30	1
9.	Altar 8		7	3	11	8	30	1
10.	Altar 9		7	4	12	8	30	1
11.	Altar- uși împărățești		7	3	12	9	30	1





12.	Strană Parte Nord		7	6	14	8	30	1
13.	Strană parte Sud		7	4	12	8	30	1
14.	Catapeteasmă		7	8	16	8	30	1
15.	Strană Nord		7	4	13	9	30	1





16.	Acoperiș + perete Nord		7	5	13	8	30	1
17.	Stană Sud		7	5	13	8	30	1
18.	Acoperiș + perete Sud		7	5	14	9	30	1
19.	Altar general Sus		7	5	14	9	30	1



20.	Altar general acoperiș Sud		7	6	14	8	30	1
21.	Strana Nord general		7	8	16	8	30	1
22.	Strana Nord acoperis		7	6	14	8	30	1
23.	Strana Nord		7	9	18	9	30	1

24.	Strana Nord + iconostas Nord		7	5	13	8	30	1
25.	Acoperiș strana Nord + catapeteasma		7	3	12	9	30	1
26.	Acoperiș catapeteasma		7	7	19	12	30	1
27.	Intrare naos general		7	4	13	9	30	1

28.	Intrare naos parte Nord		7	5	13	8	30	1
29.	Intrare naos acoperiș + perete Nord		7	4	13	9	30	1
30.	Intrare naos parte Sud		7	3	12	9	30	1
31.	Intrare naos acoperiș + perete Sud		7	3	12	9	30	1

32.	Intrare naos general acoperis		7	8	17	9	30	1
33.	Intrare naos general acoperis 2		7	5	14	9	30	1
34.	Strana Sud		7	4	12	8	30	1
35.	Pronaos 1		7	4	12	8	30	1

36.	Pronaos tavan 1		7	4	13	9	30	1
37.	Pronaos 2		7	4	13	9	30	1
38.	Pronaos tavan 2		7	4	13	9	30	1
39.	Pronaos Nord		7	4	13	9	30	1

40.	Pronaos Nord tavan		7	4	13	9	30	1
41.	Pronaos Sud		7	5	13	8	30	1
42.	Pronaos sud tavan		7	5	13	8	30	1